



Cable ID: 002

Date / Time: 03/08/2017 09:55:05 AM n = 1.4670 (1310 nm)
Cable Type: OS2 Singlemode n = 1.4680 (1550 nm)

Test Summary: PASS

Backscatter Coefficient: -79.5dB (1310 nm)
Backscatter Coefficient: -82.0dB (1550 nm)

Loss (M->R)
PASS

Date / Time: 03/08/2017 09:55:05 AM
Test Limit: *SAMPLE*
CertiFiber Pro (2834854 V5.0 Build 3)
Module: CFP-SM(3665002)
Calibration Start Date: 10/21/2016
certifiber pro remote (2792327 v5.0 build 3)
Module: CFP-SM(3665003)
Calibration Start Date: 10/21/2016

Propagation Delay (ns)	100	
Length ft	67	PASS
Limit 6562		
	1310 nm	1550 nm
Result	PASS	PASS
Loss (dB)	0.51	0.46
Limit (dB)	1.52	1.52
Margin (dB)	1.01	1.06
Reference (dBm)	-3.45	-3.09

Number of Adapters: 2
Number of Splices: 0
Connector Type: LC
Patch Length1 (ft): 7
Reference Date: 03/08/2017 07:02:56 AM
1 Jumper

Compliant Network Standards:

- | | | |
|----------------------------|---------------------------|----------------------------|
| 1000BASE-LX | 100GBASE-ER4 | 100GBASE-LR4 |
| 10GBASE-E | 10GBASE-L | 10GBASE-LRM |
| 10GBASE-LX4 | 40GBASE-ER4 | 40GBASE-FR |
| 40GBASE-LR4 | Fibre Channel 100-SM-LC-L | Fibre Channel 1200-SM-LC-L |
| Fibre Channel 1600-SM-LC-L | Fibre Channel 200-SM-LC-L | Fibre Channel 400-SM-LC-L |
| Fibre Channel 400-SM-LC-M | Fibre Channel 800-SM-LC-L | Fibre Channel 800-SM-LC-L |